



# SlipSmart Australia

ABN: 60 341 526 043

18 Stacer Street Upper Coomera, QLD 4209

Mob: 0410 657 399

email: [info@slipsmartaustralia.com.au](mailto:info@slipsmartaustralia.com.au)



Accredited for compliance with  
ISO/IEC 17025 - Testing  
Laboratory No. 15041

This report has been prepared for: *MJS Floorcoverings Pty. Ltd.*

35 Dividend Street , Mansfield QLD 4122

**Test Site: Laboratory Tests Tru Plank Cushion – Provincial Ash**

**Report Number: W1132**

**Date Tested: 02/02/2022**

**Australian Standard Applied: AS4586:2013**

**Nature and Purpose Of Tests:**

The Nature of the Wet slip tests is as per AS4586:2013 Appendix A

The purpose of the Wet slip test is to ascertain an SRV for the surfaces requested.

## WET Slip Resistance Test Report for Pedestrian Surfaces

This report has been prepared for: **MJS Floorcoverings Pty. Ltd. – Kerry Krebs,**


35 Dividend Street , Mansfield QLD 4122

**Test Site: Laboratory Tests Tru Plank Cushion – Homestead Ironbark 4mm/0.55 x 228 x 1524mm\***

Standard Applied:	AS 4586-2013	<b>Notes:</b> 1. The areas tested below were carried out <b>on site</b> using the Wessex Pendulum friction tester ID: SK1271, conditioned with grade P400 paper followed by wet 3 micron lapping film, to evaluate the frictional characteristics of the pedestrian surface. 2. SlipSmart Pty Ltd assumes no responsibility or civil liability for any actions whatsoever that may arise as a result of the tests and the publication and issue of this test report. 3. Slip test results always remain the property of SlipSmart Pty Ltd. This test report is intended for viewing solely for the named recipient identified above. 4. This report contains privileged and confidential information. The unauthorised reproduction of this report is prohibited. 5. While SlipSmart Pty Ltd takes care in preparing the reports it provides to clients, it does not warrant that the information in this particular report will be free of errors or omissions or that it will be suitable for the client's purposes.						
Rubber Type:	Slider 96							
Fixed or unfixed surface:	Unfixed							
Cleaning type:	Nil							
Topography:	Lab							
Accelerated wear (if appropriate):	n/a	Environmental Conditions:	Overcast	Date tested:	02/02/2022			
Slope:	n/a	Temperature:	25°C	Job Number:	W1132			
Sample Tested		Air Temp. °C	Floor Type	Coating	British Pendulum Number	Slip Resistance Value	Slope Correction Value	Equivalent AS4586-2013 Classification
Test area #1		25	4mm/0.55x228x1524mm vinyl	Nil	46	43	00	P3
Test area #2		25	4mm/0.55x228x1524mm vinyl	Nil	44			
Test area #3		25	4mm/0.55x228x1524mm vinyl	Nil	43			
Test area #4		25	4mm/0.55x228x1524mm vinyl	Nil	43			
Test area #5		25	4mm/0.55x228x1524mm vinyl	Nil	40			

Other observations:

Remarks: \*Sample details supplied by Client

Signatory   
Brent Vounechis

\_\_\_\_\_  
Peter Vounechis

Tested By: B Vounechis

