

# VOC Content Test Certificate

Thursday September 10<sup>th</sup>, 2009

Manufacturer: Nexus Adhesives Pty Ltd (42 Healey Road, Dandenong South Victoria 3175)

Sample Description: 2010 carpet adhesive

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</b>	<b>2010</b>
Carpet adhesive 50 grams per Litre as VOC content material	<b>40 grams per Litre as VOC content material</b>
<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>2010</b>
Carpet adhesive 50 grams per Litre as VOC content material	<b>40 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0908-35**