

VOC Content Test Certificate

Friday 19th August 2022

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: MJS Max Bond TFA Adhesive

Date Tested: November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|---|---|
| Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B | MJS Max Bond TFA Adhesive |
| General Purpose adhesives and sealants: 50 grams per Litre | 12 grams per Litre as VOC content per material |
| <p><i>We hereby certify that MJS Max Bond TFA Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD., BE (Chem. Eng.)
Senior Consultant



Luke Morley
BSc (Tech)
Consultant

P22080101